

File Message DESlock+ ESET Tell me what you want to do

Ignore Delete Archive Reply Reply All Forward More

Meeting Create New

Move OneNote Mark Unread Categorize Follow Up Translate Find Related Select Zoom

Delete Respond Quick Steps Move Tags Editing Zoom

Martyn Jones <mjoneselectrical@yahoo.co.uk> Steve Holmes 23/12/2016

**Re: ASTC - Electrical Load test**

Hi Steve

I popped in last night as promised and there's no loading problems that I can foresee

The clamp test showed the blue phase being used significantly more than red or yellow but adding 16A per phase which I believe you said the floods are going to be is not going to give you any problems

I know the court heaters are gas and having chatted to George apparently the majority of the kitchen is too so all should be fine

Have a wonderful Xmas and hopefully catch up in the new year

Regards

Martyn

Sent from my iPhone

On 21 Dec 2016, at 16:38, Steve Holmes <[stephen.holmes@chawtonhill.com](mailto:stephen.holmes@chawtonhill.com)> wrote:

Thanks Martyn,

Steve

**Stephen Michael Holmes FRICS**  
Director

<image004.png> <image003.png>

The Small Office | Elm Road | Leatherhead | Surrey | KT22 8AP

**M:** +44(0)7860 623757  
**E:** [stephen.holmes@chawtonhill.com](mailto:stephen.holmes@chawtonhill.com)  
**O:** +44(0)1372 360663  
**W:** [www.chawtonhill.com](http://www.chawtonhill.com)